



SIDEWALK UNDERDRAINS SHOULD BE TIED INTO THE STORM SEWER SYSTEM AT POINTS ABOUT A CITY BLOCK APART. UNDERDRAIN RUNS MUST NOT EXCEED 1,000 FEET IN LENGTH WITHOUT DISCHARGING INTO THE STORM DRAIN SYSTEM OR INTO AN OPEN DRAIN. THE LENGTH OF RUN MAY BE INCREASED UP TO AN ADDITIONAL 1,000 FEET IF 8" DIAMETER PIPE IS USED IN THE DOWNSTREAM 1,000 FEET SECTION OF THE RUN.

STANDARD SIDEWALK UNDERDRAIN

DRAWING NO. 500-27